



State of Vermont

AGENCY OF ENVIRONMENTAL CONSERVATION

Department of Fish and Game
Department of Forests, Parks, and Recreation
Department of Water Resources & Environmental Engineering
Natural Resources Conservation Council

Montpelier, Vermont 05602
Department of Water Resources
and
Environmental Engineering

WATER QUALITY DIVISION
September 19, 1983

| ROUTING | | |
|----------------|----------------|-----------------|
| GENERAL | | |
| TO | NOTED | DATE |
| AMD | AMD | 9/19 |
| JRC | | |
| TW | De | 9/19 |
| DLC | | |
| Robert | | 9/20/83 |
| SUSPEND TO | | |
| FILE | | (10) |

Mr. Roger Lamson
White Current Corporation
P.O. Box 414
North Hartland, VT 05052

Re: White Current Corporation
Water Quality Certification

Dear Mr. Lamson:

Pursuant to your request by phone call to Mr. Tom Willard on September 9, the last sentence of Finding #10 will be deleted from the Water Quality Certification issued September 1, 1983 for the White Current Corporation hydroelectric facility.

Finding #10 will now read as follows:

The proposed North Hartland Hydroelectric Project is located approximately 1.5 miles upstream at the U.S. Army Corps of Engineers flood control dam. An instantaneous stream flow of 23 cfs (7Q10) or greater will be released from this project at all times when available from inflow to the reservoir. If inflows fall below 23 cfs, outflows shall be maintained at the same rate as inflows.

Sincerely,

David L. Clough, Director
Water Quality Division

DLC/AMD/rh

cc: Stephen B. Sease, Director, Environmental Conservation Planning
Angelo Incerpi, Director, Fisheries Management
John Claussen, District Fisheries Biologist
Wayne Foster, Public Service Board
Gordon Stensrud, Public Service Department
Kenneth F. Plumb, Federal Energy Regulatory Commission
Cathy Castagna, U.S. Environmental Protection Agency
Vermont Electric Coop
Gordon Beckett, U.S. Fish & Wildlife Service, NH