

REMOVE AND RESET BRICK PAVERS

****From Statewide STP SDWK(11)**

- xx. DESCRIPTION. This work shall consist of removing and resetting brick pavers at the locations indicated in the Plans and as directed by the Engineer.

- xx. QUALIFICATIONS.
 - (a) The installer shall provide their installation history, including installation of brick pavers, to the Engineer.

 - (b) The installer's foreman shall have a minimum of 5 years of experience in the installation of unit paver systems of similar size and complexity.

- xx. CONSTRUCTION REQUIREMENTS. The bricks shall be removed and stacked on pallets prior to resetting.

The setting bed aggregate (ASTM No. 8) shall be spread evenly over the base course and screed to a minimum nominal 1-1/2 inch thickness.

ASTM No. 8 Gradation for Bedding Layer

Sieve Size	Percent Passing
1/2" (12.5 mm)	100
3/8" (9.5 mm)	85-100
No. 4 (4.75 mm)	10-30
No. 8 (2.36 mm)	0-10
No. 16 (1.16 mm)	

For installation on setting bed aggregate and soil subgrade, the installer should be aware that the top surface of the pavers shall be flush with the surrounding bricks after compaction.

The bedding material shall not be disturbed or pre-compacted after it has been screed.

Brick pavers shall be free of foreign material prior to resetting installation.

Brick pavers shall be set in accordance with the existing pattern.

Typical joints between the pavers shall be no less than 1/16 inch and no more than 3/16 inch in width.

Brick pavers shall be cut as necessary to accommodate field conditions and to achieve an accurate and consistent fit to the existing pattern. Pavers shall be free from stain, dirt, or dust after cutting. Paver units shall not be cut to a size smaller than one-third of a whole paver.

- xx. METHOD OF MEASUREMENT. The quantity of Special Provision (Remove and Reset Brick Pavers) to be measured for payment will be the number of square meters (square feet) brick pavers removed and reset in the complete and accepted work.

xx. BASIS OF PAYMENT. The accepted quantity of Special Provision (Remove and Reset Brick Pavers) will be paid for at the Contract unit price per square meter (square foot). Payment will be full compensation for removing, storing, and resetting brick pavers and for furnishing all materials, labor, tools, equipment, and incidental necessary to complete the work.

Removal of excess pavers not required to be reset will be paid for under Contract item 203.16.

Payment will be made under:

<u>Pay Item</u>	<u>Pay Unit</u>
900.670 Special Provision (Remove and Reset Brick Pavers)	Square Foot
900.675 Special Provision (Remove and Reset Brick Pavers)	Square Meter