

State of Vermont
PDD/Structures Design Section
National Life Building – Drawer 33
Montpelier, VT 05633-5001
www.aot.state.vt.us

[phone] 802-828-2621
[fax] 802-828-3566
[ttd] 800-253-0191

DATE: March 25, 2015

Elderlee, Inc.
Oaks Corner, NY 14578

Project Name: Colchester STP 5600(12)
Structure Identification: Bridge 12 on Mill Pond Road

The following Bridge Railing, Galvanized Steel Tubing/Concrete Combination details [Item # 525.45] and Guardrail Approach Section, Concrete Combination [Item 621.748] for the above project received via email from A.L St. Onge on April 10, 2015 have been reviewed and are being returned herewith.

The bridge railing and approach railing sheets need to be resubmitted.

Welding procedures that we received are approved, but **we are missing WPS 3025.**

Please make all changes as indicated on these drawings and resubmit them to us.

There shall be no fabrication done until all drawings and welding procedures are approved. You must provide notice to our fabrication inspector, Jeff Clark, as to the date fabrication represented by these drawings will begin. That notice must be received and acknowledged at least seven days prior to that date, as per Specification 506.03. Jeff may be contacted by phone at (802)828-0044 or email at jeff.clark@state.vt.us. Any material fabricated prior to the notification date is subject to rejection without further cause.

Sincerely,
Carolyn Carlson

Carolyn W. Carlson

Attachments

cc: [X] Resident Engineer – Josh Hulett
[X] Contractor – A.L. St. Onge
[X] Fabrication Inspector – Jeff Clark
[X] Files (Structures)