

State of Vermont
Construction Section
National Life Building, Drawer 33
Montpelier, VT 05633
www.aot.state.vt.us

[phone] 802-828-2593
[fax] 802-828-2795
[ttd] 800-253-0191

Agency of Transportation

Carl Gleason
A.L. St. Onge Contractor's, Inc.
P.O. Box 65
Montgomery, VT 05470

November 3, 2014

RE: JOHNSON BR# 030-2(26) CONTRACTOR EROSION PREVENTION AND SEDIMENT CONTROL PLAN

Dear Carl:

VTrans has completed its review of the Contractor Erosion Prevention and Sediment Control (EPSC) Plan submitted October 31, 2014 via SharePoint. The Plan is considered acceptable with the stipulation that the below comments are addressed prior the associated work being performed.

However you plan to isolate the work area to install stone fill for abutment 1 and 2 from the stream you must quantify your footprint below ordinary high water if that deviates from what is shown in the Contract plans. You must amend the Corps of Engineers Permit if the footprint increases. You must also have in writing approval from the ANR River Management Engineer prior to starting those activities.

The schedule is showing work outside the in-water work dates of June 1- October 1 as stipulated in the Title 19, Stream Alterations Permit and you must have in writing approval to work outside those dates from the ANR River Management Engineer before starting those activities.

If you would like to work outside the construction limits as shown in the Contract plans you must first submit an Off-Site Activity form per specification 105.25 for approval.

If you have any questions, please contact me at (802) 828-5483.

Sincerely,

William Farley P.E., CPESC
VTrans Assistant Construction Environmental Engineer

cc: Jeff Cota, VTrans Resident Engineer
Chris Williams, VTrans NW Regional Engineer
Carolyn Carlson, VTrans Project Manager
Andrea Wright, VTrans Construction Environmental Engineer
Project File