



**TRANSMITTAL NO. 004**

To: Parsons, Brinckerhoff, Quade, & Douglas, Inc.  
75 Arlington Street, 9<sup>th</sup> Floor  
Boston, MA 02116

Attention: Mr. Daryl Sargent


Project: Bradford-Newbury IM BPNT (14)  
Bridge Painting of Five Bridges in the Towns of Bradford and Newbury, VT

Date: July 13, 2015

**WE ARE SENDING:**

COPIES	DESCRIPTION	DISPOSITION
1	<b>KTA Submittal Review Letter</b> Monoko, LLC - Submittal No. 27 - Paint Certifications	See attached submittal review letter for additional comments

**COMMENTS:**

Signed   
Jeff Towill, Project Manager

350274

*If enclosures are not as noted, kindly notify us at once*



July 13, 2015  
Via e-mail: sargent@pbworld.com

Mr. Daryl Sargent  
Parsons, Brinckerhoff, Quade, & Douglas, Inc.  
75 Arlington Street, 9<sup>th</sup> Floor  
Boston, MA 02116

**SUBJECT: Bradford-Newbury IM BPNT (14);  
Bridge Painting of Five Bridges in the Towns of  
Bradford & Newbury; Review of Paint Certification**

Dear Mr. Sargent:

In accordance with our agreement, KTA-Tator, Inc. (KTA) has reviewed the paint certification information submitted by Monoko, LLC for the above referenced project. As directed, the submittal was reviewed for compliance with the requirements of a previous specification that are identical to the requirements for this project – Section 900 of the Special Provisions for the St. Albans-Highgate project (AC IM BPNT (4)) dated September 3, 2009.

The paint certification information consisted of Sherwin-Williams' Certificates of Analysis for paint batches of Zinc Clad III HS (primer) and Macropoxy 646 Fast Cure Epoxy (intermediate coat). The Certificates indicate the batches are compliant with the Sherwin-Williams property requirements listed for each material.

Section 34(e) of the Special Provisions (Paint Manufacturer Certification and Letters) does not appear to require any specific certifications for the paint system, except for a penetrating sealer, as addressed in KTA's review letter dated July 6, 2015.

If you have any questions or need additional information, please do not hesitate to contact me at (412) 788-1300, extension 216, or by e-mail at [jhelsel@kta.com](mailto:jhelsel@kta.com).

Sincerely,

**KTA-TATOR, INC.**

A handwritten signature in black ink that reads "Jayson L. Helsel". The signature is written in a cursive, flowing style.

Jayson L. Helsel, P.E.  
Senior Consultant

JLH:JDM:am  
350274  
cc: Jeff Towill – KTA

**NOTICE:** This report represents the opinion of KTA-TATOR, INC. This report is issued in conformance with generally acceptable industry practices. While customary precautions were taken to verify that the information gathered and presented is accurate, complete and technically correct, it is based on the information, data, time, materials, and/or samples afforded.