

J.P. Carrara & Sons, Inc.
 2464 CASE STREET
 MIDDLEBURY, VERMONT 05753

TEL (802) 388-6363
 FAX (802) 388-9010

TO: **Cold River Bridges, LLC**

PO Box 1076
Walpole, NH 03608

DATE:	April 25, 2014	JOB NO.:	23416-014
ATTENTION:	Chad Contaldi		
RE:	Route 100 Bridge #124		
	Pittsfield, VT		
	ER BRF 022-1 (23)		
	Cold River PO# 001091		
	P 603-756-9300	F 603-756-9303	

WE ARE SENDING YOU Attached Under separate cover via _____ the following items:

Shop Drawings Prints Plans Samples Specifications

Copy of Letter Change Order Other: _____

COPIES	DATE	NO.	DESCRIPTION
1			Shop Drawngs: Dated 2/3/14 REVISION #1 DATED 4/21/14
			Sheets: CI, FI-F2, NBI-NB4A, MI
			NEW FLANGE REINFORCING DRAWINGS: NBIB, NBIC, NBID, NBIE
1			Lifting Loop Calculations: Dated 2/13/14 REVISION #1 DATED 4/3/14

THESE ARE TRANSMITTED as checked below :

For approval Approved as submitted Resubmit _____ copies for approval

For your use Approved as noted Submit _____ copies for distribution

As requested Returned for corrections Return _____ corrected prints

For review and comment _____

FOR BIDS DUE _____ 20 _____ PRINTS RETURNED AFTER LOAN TO US

REMARKS **Chad- Please see attached shop drawings.**

Please note that we have made an alteration from the contract drawings to the key way geometry to accommodate our forming system, see Detail A on sheet FI.

We have used this key way geometry on several other VTAOT NEXT beam projects.

We have added Sheets: NBI A-E showing flange reinforcing per conversations with VTAOT.

Whatever you can do to expedite approval would be appreciated.

Thanks

COPY TO File

SIGNED :



Michael A. Davis

If enclosures are not as noted, please notify us at once.