

State of Vermont
PDD/Structures Design Section
National Life Building – Drawer 33
Montpelier, VT 05633-5001
www.aot.state.vt.us

[phone] 802-828-2621
[fax] 802-828-3566
[ttd] 800-253-0191

Agency of Transportation

DATE: May 21, 2015

Highway Safety
Glastonbury, CT

**Project Name: Richford Project #: BRF 030-2(29)
Structure Identification: Bridge #6 on TH 3**

The following Items: **525.33 “Bridge Railing, Galvanized 2 Rail Box Beam” and 621.72, “Guardrail Approach Section, Galvanized 2 Rail Box Beam”** details (Vendor’s Job #2039), transmitted and received by our office on May 21, 2015 have been reviewed and are being returned herewith.

Sheets: **1 -3 are to be resubmitted. There are still issues with the drawings.**

However, the anchor bolt spacing as noted on these drawings are acceptable.

Welding Procedures are approved, but we will hold until the plans are resubmitted and approved.

If you have any questions, I can be reached at (802) 828-0048.

Sincerely,

Carolyn W. Carlson

Carolyn W. Carlson, PE
Structures Project Manager

Attachments

cc: [x] Resident Engineer – (email) Scott Wheatley
[x] Shop Inspector – (email) Jeff Clark
[x] Contractor – (email) GW Tatro
[x] Sub Contractor- F.R. Lafayette
[x] Files (Structures) – letter only