

State of Vermont  
PDD/Structures Design Section  
National Life Building – Drawer 33  
Montpelier, VT 05633-5001  
[www.aot.state.vt.us](http://www.aot.state.vt.us)

[phone] 802-828-2621  
[fax] 802-828-3566  
[ttd] 800-253-0191

Agency of Transportation

Concrete Systems Inc.  
9 Commercial Street  
Hudson, NH 03051

May 14, 2015

Project Name: Richford Project #: BRF 0302(29)

Structure Identification: **Bridge 6 over the Berry Brook**

The following Precast Concrete Structure (28' x 6' x 29' Frame or Arch Type), Precast Concrete Structure (Pedestal Walls Abutment 1 and 2) and Precast Concrete Structure (Wingwalls 1 thru 4) details [Item 540.10, Precast Concrete Structures] for the above project (Vendor's Job # C22312) transmitted through SharePoint on April 22, 2015 have been reviewed and are being returned herewith.

**All sheets need to be resubmitted.** We have reviewed the updated calculations that were uploaded recently and they are fine. However, please recalculate as you will note that the wingwalls are higher than in your design due to changes on the attached shop drawings. Please note that we can not give any final approval until we receive the lifting loop calculations and transportation, handling and storage details, and notes about your cure method.

There shall be no fabrication done until all drawings have been approved.

Please remember that Jim Wild (802-828-6931) needs at least **Two weeks Advance Notification** with regards to fabrication dates of all the precast structures. Any material fabricated prior to the notification date is subject to rejection without further cause. Also, please be reminded that when we give you a final approval of these drawings that a Pre-Production meeting will need to be scheduled with Jim Wild as per our specifications.

If you have any questions, please contact me at (802) 828-0048.

Sincerely,

*Carolyn Carlson*

Carolyn W. Carlson, PE

Attachments

cc: [X] Resident Engineer Scott Wheatley  
[X] Shop Inspector Jim Wild  
[X] Contractor GW Tatro  
[X] CWC