

State of Vermont
PDD/Structures Design Section
National Life Building – Drawer 33
Montpelier, VT 05633-5001
www.aot.state.vt.us

Agency of Transportation

[phone] 802-828-2621
[fax] 802-828-3566
[ttd] 800-253-0191

April 15, 2015

Casco Bay Steel Structures, Inc.
1 Wallace Ave.
South Portland, ME 04106

Project Name: Rutland City Project #: BRF 3000(16)

Structure Identification: River Street (Bridge 2) Over the Otter Creek

The following expansion joint details [Item 516.11, Bridge Expansion Joint, Vermont] for the above project (Vendor's Job #597) transmitted via email from Kubricky Construction Corp. on April 3, 2015 have been reviewed and are being returned herewith.


Sheets: Please resubmit the entire package.
(Please note comments in red and resubmit for final approval.)

The Welding procedures are not approved. Please resubmit.

We also recommend that the Trafficguard EP35 coating be replaced with either Galvagrut or SlipNot.

There shall be no fabrication done until all drawings and welding procedures are approved. Any material fabricated prior to the notification date is subject to rejection.

Sincerely,



Carolyn W. Carlson
Structures Project Manager

Attachments

cc: [X] Resident Engineer - letter only Tim Pockette
[X] Shop Inspector - letter only Jeff Clark
[X] Contractor - letter only Kubricky Construction Corp.
[X] Files