

State of Vermont
Construction Section
National Life Building, Drawer 33
Montpelier, VT 05633
www.aot.state.vt.us

[phone] 802-828-2593
[fax] 802-828-2795
[ttd] 800-253-0191

Agency of Transportation

Harper T Callahan
Kubricky Construction Corporation
269 Ballard Road
Wilton, VT 12831

December 17, 2014

**RE: RUTLAND CITY BRF 3000(16) CONTRACTOR EROSION PREVENTION AND
SEDIMENT CONTROL PLAN**

Dear Harper:

VTrans has completed its review of the Contractor Erosion Prevention and Sediment Control (EPSC) Plan received via SharePoint on November 24th, 2014. The Plan is considered acceptable at this time. Please ensure the comments below are addressed.

- **The VT DEC Construction General Permit (CGP)-** If the following points are not addressed you will be in violation of the CGP.
 - The cover letter has several bullets that direct you to certain documents you must have in order to be compliant with the permit. Please ensure you have these documents on-project. It also directs you to post the Notice of Authorization on a public board. Please ensure this has been done prior to work starting.
 - In order to be compliant with VT Water Quality Standards you must be able to prove any discharge water that leaves the site is within those standards. This will require you to have a Turbidity meter on-site.
 - It will be important that the EPSC Plan be up to date and that all forms and documents are readily available should VT DEC visit the site.
 - The staging area adjacent to the project on the **Granger** property must be included in the

CGP. You must reevaluate the permit to ensure that it is still valid and file the appropriate paperwork to verify you have addressed this change in footprint. Refer to the On-Site Plan Coordinator Manual as noted in the CGP cover letter for guidance.

- The **Schedule** as submitted has conflicts such as placing stone fill around substructures after steel has been set. It appears that it has not been updated since the previous EPSC Plan submittal. I am in no way accepting or denying your schedule.

If you have any questions, please feel free to contact me at (802) 828-5483.

Sincerely,

A handwritten signature in black ink that reads "William Farley". The signature is written in a cursive, flowing style.

William Farley P.E., CPESC

VTrans Assistant Construction Environmental Engineer

cc: Tim Pockette, VTrans Resident Engineer

Mark Mackintosh, VTrans SW Regional Engineer

Carolyn Carlson, VTrans Consultant Project Manager

Andrea Wright, VTrans Construction Environmental Engineer

Project File
