



Entergy Nuclear Operations, Inc.
Vermont Yankee
320 Governor Hunt Rd.
Vernon, VT 05354
Tel 802 257 7711

EM

Michael J. Colomb
Site Vice President

BVY 11-008

February 2, 2011

ATTN: Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

SUBJECT: Technical Specifications Proposed Change No. 290
Administrative Changes – Supplement 1
Vermont Yankee Nuclear Power Station
Docket No. 50-271
License No. DPR-28

2011 FEB -3 A 9: 29
STATE OF VERMONT
DEPT OF PUBLIC SERVICE
MONTPELIER, VT.
05620-2601

REFERENCE: 1. Letter, Entergy Nuclear Operations to USNRC, "Technical Specifications Proposed Change No. 290 Administrative Changes," BVY 10-017, dated April 13, 2010

Dear Sir or Madam:

In Reference 1, Entergy Nuclear Operations (ENO) proposed an amendment to Operating License DPR-28 for the Vermont Yankee Nuclear Power Station.

During their review, the NRC staff requested that ENO revise the proposed wording to Technical Specification (TS) 3.7.A.8 as follows:

"If Specification 3.7.A.1 through 3.7.A.6 are not met, an orderly shutdown shall be initiated and the reactor shall be in a cold shutdown condition within 24 hours."

Attachment 1 provides the revised TS page 151 to reflect this change. This change is considered administrative and does not affect the conclusions of the no significant hazards consideration determination provided in Reference 1.

There are no new regulatory commitments made in this letter.

If you have any questions on this transmittal, please contact Mr. Robert Wanczyk at 802-451-3166.

I declare under penalty of perjury that the foregoing is true and correct. Executed on February 2, 2011.

Sincerely,

MJC/JMD

Attachment: 1. Retyped Technical Specifications Page 151

cc: Mr. William M. Dean
Regional Administrator, Region 1
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406-1415

Mr. James S. Kim, Project Manager
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Mail Stop O8C2A
Washington, DC 20555

USNRC Resident Inspector
Entergy Nuclear Vermont Yankee, LLC
320 Governor Hunt Rd
Vernon, Vermont 05354

Ms. Elizabeth Miller
Commissioner
VT Department of Public Service
112 State Street – Drawer 20
Montpelier, Vermont 05620-2601

Attachment 1

Vermont Yankee Nuclear Power Station

Proposed Change No. 290

Retyped Technical Specifications Page 151