



Entergy Nuclear Operations, Inc.
Vermont Yankee
320 Governor Hunt Rd
Vernon, VT 05354
Tel 802 257 7711

EM

Robert J. Wanczyk
Licensing Manager

STATE OF VERMONT
DEPT. OF PUBLIC SERVICE
MONTPELIER, VT.
05620-2601
2012 FEB 08 A 9:13

BVY 12-014

February 7, 2012

ATTN: Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

SUBJECT: Clarification to Response to Request for Additional Information Regarding
Core Plate Hold-down Bolt Inspection Plan and Analysis
Vermont Yankee Nuclear Power Station
Docket No. 50-271
License No. DPR-28

REFERENCES: 1. Letter, Entergy to USNRC, "Response to Request for Additional
Information for Core Plate Hold-down Bolt Inspection Plan and
Analysis," BVY 12-008, dated February 1, 2012

Dear Sir or Madam:

In Reference 1, Vermont Yankee Nuclear Power Station (VYNPS) submitted a response to a Request for Additional Information (RAI) regarding the core plate hold-down bolt inspection plan and analysis. In response to RAI No. 3, VYNPS stated that it will inspect 50% of the core plate hold-down bolts every refueling outage (RFO), commencing in RFO 31. In the list of regulatory commitments provided in the same letter, VYNPS stated that it will inspect 50% of the core plate hold-down bolts every other refueling outage, commencing in RFO 31. The purpose of this letter is to clarify that the response to RAI No. 3 should have stated that VYNPS will inspect 50% of the core plate hold-down bolts every other refueling outage, commencing in RFO 31.

This letter contains no new or revised regulatory commitments.

Should you have any questions or require additional information concerning this submittal, please contact me at 802-451-3166.

Sincerely,

[RJW/PLC]

cc: Mr. William M. Dean, Regional Administrator
U.S. Nuclear Regulatory Commission, Region 1
475 Allendale Road
King of Prussia, PA 19406-1415

Mr. James S. Kim, Project Manager
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Mail Stop O8C2A
Washington, DC 20555

USNRC Resident Inspector
Vermont Yankee Nuclear Power Station
320 Governor Hunt Rd
Vernon, VT 05354

Ms. Elizabeth Miller, Commissioner
VT Department of Public Service
112 State Street – Drawer 20
Montpelier, Vermont 05620-2601